

ANNUAL DRINKING WATER QUALITY REPORT FOR 2013

**VILLAGE OF WAPPINGERS FALLS MUNICIPAL WATER SYSTEM
2582 SOUTH AVENUE
WAPPINGERS FALLS, NEW YORK 12590
(PUBLIC WATER SUPPLY ID# 1302783)**

INTRODUCTION:

To comply with State and Federal regulations, the Village of Wappingers Falls Municipal Water System will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact the office of the Village of Wappinger Falls Water Department, 2582 South Avenue, Wappingers Falls, New York 12590, (845) 297-8773, extension 8. We want you to be informed about your drinking water. If you want to learn more, please attend our regularly scheduled meetings of the Village Board of Water Commissioners on the Monday before the second Wednesday of each month at 4:30 p.m. at the new Water Treatment Facility located at 2784 West Main Street, Wappingers Falls, New York.

WHERE DOES OUR WATER COME FROM ?

In general, the sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic and chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Until December 28, 2011 the Village water supply was purchased from and provided by the City/ Town of Poughkeepsie Joint Water Board via the interconnection on DeLavernne Avenue. As of December 28, 2011 use of the interconnection was discontinued.

All water is now supplied by the new Village of Wappingers Falls Water Treatment Facility. Construction of the new Village of Wappingers Falls Water Treatment Facility began in the Spring of 2010, and was completed in December of 2011. The Plant began providing finished water to the Village customers on December 28, 2011.

The source of the water provided by the new Village of Wappingers Falls Water Treatment Facility is from three (3) active wells located at the 8.0 acre Village wellfield.

- Wells #1 and #2 (inactive) were both formally abandoned in 2010/11.
- Well #3 is a 12" x 18" gravel pack type well, 95 feet in depth, originally constructed in 1959 and re-drilled in 1997. Well No. 3 was previously taken off line in October 2006. It was placed back into service beginning on September 13, 2011, and now produces approximately 150 gpm.
- Well #4 (inactive) is a 12" x 18" gravel pack type well 100 feet in depth, originally constructed in 1965 and re-drilled in 1997. Well No. 4 was taken offline in October of 2003 due to an increase in iron content.
- Well #5 (inactive) is a 24" x 30" gravel pack type well, 105 feet in depth, originally constructed in 1984. Well #5 was taken off line in 1994 due to significant increases in iron content.
- Well No. 7 and No. 7A are both 16" x 24" gravel pack type wells. Well No. 7 is 99 feet in depth and was originally constructed in 2005. Well No. 7A is 98 feet in depth and was originally constructed in 2010. Both wells were tested for production and water quality immediately following their construction. The quality of water in these wells was deemed adequate for drinking water purposes. Each well was tested at a production rate of approximately 600 gallons of water per minute. Further analysis confirmed that either well can produce a maximum flow of 600 GPM of water under theoretical drought conditions. Both Well No. 7 and No. 7A were placed back into service beginning on September 13, 2011.

The new Village of Wappingers Falls Water Treatment Plant utilizes state of the art technology to treat the well water supply. This includes softening of up to 700 gallons per minute (GPM) utilizing an ion exchange type softener system. Finished water hardness is approximately 9 grains. Disinfection is provided through the use of ultraviolet light reactors, followed by a minimal dose of chlorine to provide a residual throughout the distribution system. The Plant facilities and wells are partially automated, and controlled via a Supervisory Control System (SCADA). The Plant is rated at a maximum production capacity of approximately 1 million gallons per day (MGD).

The Village of Wappingers Falls water storage facilities consist of three (3) tanks.

- The Wenliss Tank has a capacity of 1.4 million gallons.
- The DeLavernge Tank has a capacity of 545,000 gallons.
- The Hillside Tank (inactive) has a capacity of 170,000 gallons.

During 2013 our system did not experience any restriction of our water source.

The NYSDOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumer is, or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected, if any. The source water assessments provide resource managers with additional information for protecting source waters into the future.

The source water assessment has rated our well field water source as having an elevated susceptibility to microbial and nitrate contamination. These ratings are due primarily to the residential land use and related activities in the assessment area. In addition, the wells draw from the sand and gravel aquifer, and the overlying soils may not provide adequate protection from potential contamination. The county and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning and education programs.

FACTS AND FIGURES:

The Village of Wappingers Falls Municipal Water System serves an estimated 5,522 (2010 Census figure) people through approximately 1,520 service connections.

In 2013 the new Village of Wappingers Falls Water Treatment Facility had a total treated water output of approximately 203 million gallons, or 555,732 gallons per average day. The total billed water during the same period was approximately 155 million gallons, or 424,289 gallons per average day. Estimated losses, municipal usage, flushing of the water system, fire- fighting usage, and/or non-billed water theft accounted for approximately 48 million gallons (23.65 % \pm). In 2013, Village of Wappingers Falls residential users were charged a bi-monthly base rate of \$ 38.00 per unit (\$ 19.00 for seniors). Additionally, residential users were billed based on bi-monthly water meter readings at the rate of \$ 2.08 per 100 cubic feet of water (or 748 gallons) up to 1200 cubic feet, and \$ 4.25 per 100 cubic feet over 1200 cubic feet.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER ?

As the State regulations require, the Village of Wappingers Falls Water System routinely tests your drinking water for numerous contaminants. Testing is performed in conformance with the provisions of Part 5 of the New York State Sanitary Code. Subsequent to the completion of the new Village Water Treatment Facility, a new testing protocol was implemented with the Dutchess County Health Department. A brief outline of said testing is as follows.

- **Daily Sampling:** Both the source (raw) water and the finished treated water are tested each day for iron, manganese and hardness. The distribution system is tested each day for free chlorine residual. The UV disinfection system continuously tests finished (treated) water to insure adequate dosage.
- **Microbiological:** Six (6) total samples are collected and analyzed for coliform bacteria monthly.
- **Chloride:** 1 sample to be taken yearly at entry point.
- **GUDI- E Coli:** 1 sample to be taken each quarter from the raw well water for 4 consecutive quarters.
- **Iron:** 1 sample to be taken each calendar quarter from the entry point and 1 sample to be collected yearly from the raw well water.
- **Manganese:** 1 sample to be taken each calendar quarter from the entry point and 1 sample to be collected yearly from the raw well water.
- **Nitrate:** 1 sample to be taken yearly at the entry point.
- **Lead and Copper:** 40 samples to be taken from the distribution system.
- **Radiological Samples:** 1 sample to be taken each calendar quarter from the entry point for 4 consecutive quarters.
- **Primary Inorganic Chemicals:** 1 sample to be taken from the entry point every three years.
- **Disinfection Byproducts:** 1 sample to be taken each calendar quarter from a sampling point representing the maximum residence time in the distribution system.
- **Principle Organic Chemicals (POC's):** 1 sample to be taken yearly from the raw well water.
- **Synthetic Organic Chemicals (SOC's):** Waiver issued by DCHD on 12/18/12 until 12/31/15.
- **Sodium:** 1 sample to be taken yearly at entry point.
- **Asbestos:** 1 sample to be taken every nine years from the distribution system.

Complete analytic results are available for public inspection at the offices of the Village of Wappingers Falls Water Department, 2582 South Avenue, Wappingers Falls, New York 12590 (845) 297-8773.

The following table depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg./ Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
INORGANIC CONTAMINANTS							
Chloride	No	12/04/13	74	mg/L	N/A	MCL=250	Naturally occurring. Road Salt, Water Softeners, Animal Waste
Iron	No	10/22/13	76	ug/L	N/A	MCL=300	Naturally Occurring
Manganese	No	10/22/13	13	ug/L	N/A	MCL=300	Naturally Occurring
Nitrate	No	10/21/13	0.88	mg/L	10	MCL=10	Runoff from Fertilizer Use. Leaching from septic tanks. Erosion of natural deposits.
Lead	No	6/18/13	7.8 ¹ U - 14	ug/L	0	AL=15 See Note 1	Corrosion of household plumbing system
Copper	No	6/18/13	0.90 ¹ 0.022- 1.1	mg/L	1.3	AL=1.3 See Note 1	Corrosion of household plumbing systems
Sodium	No	4/19/13	140 ²	mg/L	N/A	See Note 2	Naturally Occurring. Road Salt, Water Softeners, Animal Waste
Barium	No	10/03/12	0.0093	mg/L	2	MCL=2	Erosion of Natural Deposits
DISINFECTION BYPRODUCTS							
Total Tri-halomethanes	No	12/12/12 (most recent)	9.9 Avg. ³ 0.50- 19.9	ug/L	N/A	MCL=80	By-product of Drinking Water Disinfection
Haloacetic Acids (HAA)	No	12/12/12 (most recent)	1.7 Avg. ³ U – 3.8	ug/L	N/A	MCL = 60	By-product of Drinking Water Disinfection
RADIOACTIVE CONTAMINANTS							
Combined Radium 226 & 228	No	03/15/12 (most recent)	0.87	pCi/L	0	MCL=5	Erosion of Natural Deposits.
PRINCIPLE ORGANIC CHEMICALS (POC's)							
MTBE	No	12/04/13	0.59	ug/L	N/A	MCL=10	Release from gasoline storage tanks. MTBE is an octane enhancer in unleaded gas.

¹ The level presented represents the 90th percentile of the 20 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead/ copper values detected in your water system. In this case, 20 samples were collected at your water system and the 90th percentile value was the 18th highest value. The action level for lead and copper was not exceeded at any of the sites tested. These are the most recent results as required by the local Health Department.

² Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

³ This level represents the annual quarterly average calculated from data collected (calendar year 2012 only).

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Dutchess County Health Department at (845) 486-3400.

DEFINITIONS:

- **Maximum Contaminant Level (MCL)**: The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLGs as feasible.
- **Maximum Contaminant Level Goal (MCLG)**: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.
- **Maximum Residual Disinfection Level (MRDL)**: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG)**: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefit of the use of disinfectants to control microbial contamination.
- **Action Level (AL)**: The concentration of a contaminant that, if exceeded, triggers treatment or other requirements, which a water system must follow.
- **Treatment Technique (TT)**: A required process intended to reduce the level of a contaminant in drinking water.
- **Non-Detects (ND)**: Laboratory analysis indicates that the constituent is not present.
- **Nephelometric Turbidity Unit) NTU)**: A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **Milligrams per liter (mg/L)**: Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).
- **Micrograms per liter (ug/L)**: Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).
- **Nanograms per liter (ng/L)**: Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion – ppt).
- **Picocuries per Liter (pCi/L)**: A measure of the radioactivity in Water.
- **Millirems per year (mrem/yr)**: A measure of radiation absorbed by the body.
- **Million Fibers per Liter (MFL)**: A measure of the presence of asbestos fibers that are longer than 10 micrometers.

WHAT DOES THIS INFORMATION MEAN ?

As you can see from the previous table, our system had no violations. We have learned through our testing that some of the listed contaminants have been detected; however, these contaminants were detected below New York State requirements.

“If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants and young children. It is possible that lead levels in your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. The Village of Wappingers Falls Water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested (by your lab at your own expense). Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>”.

IS OUR WATER SYSTEM MEETING OTHER RULES GOVERNING OPERATIONS?

During 2013, the Village of Wappingers Falls Water System was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS ?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium*, *Giardia* and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

In general, the use of water softeners creates the possibility of increasing the sodium content in the finished water. As per NYS Drinking Water Part 5 “Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets”. The most recent sodium level for our finished water was 140 mg/l (4/19/13). As required, this information is provided on the bi-monthly billing statements.

WHY SAVE WATER AND HOW TO AVOID WASTING IT ?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water.

- Saving water saves energy and some of the costs associated with both of these necessities of life.
- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire-fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and be looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year
- Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances. Then check the meter after 15 minutes. If the red dial on the bottom right of the new style meters moves, you have a leak.

SYSTEM IMPROVEMENTS: JANUARY 2013 - DECEMBER 2013:

In 2013, the Village of Wappingers Falls Water System made the following capital improvements:

- Ongoing start up and fine tuning of the new Village of Wappingers Falls Water Treatment Facility.
- Completion of a new 12" PVC water main, hydrants and appurtenances from McKinley Street into the Industrial Park (old bridge).
- Completion of a new 8" DIP water main, hydrants and appurtenances connecting lower Market Street with Franklindale Avenue (through the Creekside Springs development).
- Installation of a new 8" DIP water main, hydrant and appurtenances from market Street into the new Highway Garage facility.
- Completion of new 8" DIP water main, hydrants and appurtenances through the Riverbend II site.
- Completion of the new solar panel array to provide electric power to the Water Treatment Facility.
- A total of 30 ± water leaks and/or faulty curb valves were identified and repaired during 2013.
- Continued with replacement of Commercial water service meters (4), and residential service meters/ radio read transmitters (12).
- Continued with cross control ordinance enforcement and backflow prevention device testing program.

FUTURE CAPITAL IMPROVEMENTS:

The Village Board of Trustees, in coordination with the water department and the highway department, has adopted a capital improvement plan to replace water mains, sewer mains, and repave streets, which includes street surface replacement, curbs, drainage and sidewalks, throughout the Village. The adopted plan can be reviewed at Village Hall or at the Village website: www.wappingersfallsny.gov.

Planned Future Capital Improvements:

- Industrial Park Water Line Replacement
- Well-head and Aquifer Protection Programs.
- Old mains and water infra-structure replacement under the Village Capital Improvement Plan.
- Backflow Prevention Program.
- 300,000 gallon elevated storage tank – east side of Route 9

CLOSING:

Thank you for allowing us to continue to provide your family with quality drinking water this year. We ask that all our customers help us protect our water sources, which are the heart of our community and our way of life. Please call our office if you have questions.

Village of Wappingers Falls Water Commissioners and Water Department -
Patrick Chase, Chairman
Matthew Alexander, Commissioner
Jennifer Niznik, Commissioner
Vincent Benedetto, Commissioner
Marie White, Water Department Clerk
Ken Crusie, Water System Operator
Patrick Ward, Water System Operator
John Kozak, Water System Operator
Peter J. Paggi, Superintendent of Public Works
KC Engineering & Land Surveying, P.C. – Joseph E. Paggi, Jr., P.E.

